



TEST RESULTS

14.0 SUMMARY OF RESULTS:

Test Method	Test Conditions	Test Conclusion
Specimen # 1 (E-21)		
Uniform Static Load Test (ASTM E330 & TAS 202)	+/- 65 psf Design Pressure	PASS
Large Missile Impact Test (TAS 201 and ASTM E1886/E1996)	9-lb, 2 x 4 @ 50ft/sec	PASS
Cyclic Load Test (TAS 203 and ASTM E1996)	+/- 65 psf Design Pressure	PASS
Specimen # 2 (E-22)		
Air Infiltration Test (ASTM E283 & TAS 202)	1.57 psf & 6.24 psf	PASS
Uniform Static Load Test (ASTM E330 & TAS 202)	+/- 65 psf Design Pressure	PASS
Forced Entry Resistance Test (TAS 202)	300-lb.	PASS

ENGINEER OF RECORD

5/4/07